


<b>Proyecto</b>	JARDÍN INFANTIL - BOSA - CAMPO VERDE. BOGOTÁ, D.C.		
<b>Sondeo No.</b>	P - 2	<b>Fecha</b>	02-may-18
<b>Muestra No.</b>	M - 4	<b>Realizado</b>	Luis Carlos Mendoza P.
<b>Profundidad, m</b>	3,60 - 4,20		
<b>Descripción</b>	Arcilla, algo de limo, gris claro habano, vetas amarillas.		

Tiempo, min	$\delta \times 10^{-4}$ , in	$\delta$ , cm
0,07	4,0	0,001
0,25	6,0	0,002
0,57	7,0	0,002
1,00	8,0	0,002
1,57	10,0	0,003
2,25	12,0	0,003
3,07	15,0	0,004
4,00	17,0	0,004
6,25	22,0	0,006
9,00	28,0	0,007
12,25	31,0	0,008
16,00	41,0	0,010
25,00	53,0	0,013
36,00	66,0	0,017
49,00	78,0	0,020
64,00	116,0	0,029
81,00	145,0	0,037
100,00	185,0	0,047
121,00	223,0	0,057
144,00	248,0	0,063
240,00	326,0	0,083
1080,00	826,0	0,210
1440,00	987,0	0,251
2880,00	1293,0	0,328
4320,00	1366,0	0,347



Diámetro de la muestra, cm	4,730
Altura de la muestra, cm	2,590
Carga vertical, kgf	1,229
Presión vertical, kgf/cm <sup>2</sup>	0,07
Presión vertical, kPa	7,0
Grado de expansión (Holtz y Gibbs)	Medio

Expansión medida en consolidómetro bajo una presión vertical de 7,0 kPa, % (Holtz y Gibbs)	<b>13,396</b>
--	---------------

Revisó: \_\_\_\_\_